



Municipal Corporation, Jalandhar



From

Assistant Health Officer,
Municipal Corporation
Jalandhar.

To

Swami Sant Dass Public School
Udaseen-Ashram, J.P Nagar
Jalandhar (Pb).

Memo No. 844/HO

Dated. 2/6/2023


Sub: -


Certificate for health & Sanitation for the year 2023-2024.

Reference your letter no. SSDPS/2023/XI-3227 Dated .18-05-2023 in the subject cited above.

As per the report of CSI/SI your institution "Swami Sant Dass Public School, Udaseen-Ashram, J.P Nagar, Jalandhar" is hereby certified for health & Sanitation as proper hygiene and sanitation is being maintained by the institution. This certificate is being issued on the condition you will comply with the Municipal Solid Waste Management & Handling Rules 2016 regarding collection, segregation and transportation of Solid Waste.

Area Sanitary Inspector will inspect the site periodically, if there is any negligence found, penalty will be imposed. It may further be noted that failure to comply with the above condition/permission so granted will be cancelled.


Assistant Health Officer
Municipal Corporation
Jalandhar


PRESIDENT
SWAMI SANT DASS PUBLIC SCHOOL
UDASIN ASHRAM, J.P. NAGAR
JALANDHAR


PRINCIPAL
SWAMI SANT DASS PUBLIC SCHOOL
UDASIN ASHRAM, J.P. NAGAR
JALANDHAR

MUNICIPAL CORPORATION JALANDHAR

WATER TESTING LABORATORY

(WATER ANALYSIS REPORT)


REF. NO:- 312 SAMPLE PROVIDED BY:- Swami Sant Dass Public School

REF. DT. 19/5/23 SAMPLE COLLECTED:- J.P. Nagar, Jalandhar.

SR. NO.	TEST	REQUIRED LIMIT IS10500	SAMPLE (1)	SAMPLE (2)	SAMPLE (3)	SAMPLE (4)
1	COLOUR	5 HAZEN	Colourless			
2	ODOUR	UNOBJECTIONABLE	Odourless			
3	TASTE	AGREEABLE	No smell			
4	PH	6.5-8.5	7.3			
5	TOTAL HARDNESS AS CaCO ₃	300 mg/l	130			
6	DISSOLVED SOLIDS(TDS)	500 ppm	240			
7	ALKALINITY	200 mg/l	140			
8	CALCIUM AS Ca++	75 mg/l	48.0			
9	IRON	0.3 mg/l	0.1			
10	CHLORIDE	250 mg/l	36.0			
11	SULPHATE	150 mg/l	—			
12	NITRATES	4.5 mg/l	0.2			
13	RESIDUAL CHLORINE	0.2 mg/l	ND			
14	FLUORIDE	1.0 mg/l	0.1			
15	LEAD	0.05 mg/l	—			
	BACTERIAL TEST					
	TOTAL COLIFORM COUNT		/			
	BY MPN METHOD PER 100ML		ND			
	TOTAL E. COLI COUNT		/			
	BY MPN METHOD PER 100ML		/			
	TOTAL E-COLI COUNT		/			
	BY COLONY COUNT METHOD		/			

REMARKS:-

Provided water sample found satisfactory as per the applied test.



Chaitanya
PRESIDENT

SWAMI SANT DASS PUBLIC SCHOOL
UDASIN ASHRAM, J.P. NAGAR
JALANDHAR

Neelkamal Analyst
Municipal Corporation
22/5/23

Sania
PRINCIPAL

SWAMI SANT DASS PUBLIC SCHOOL
UDASIN ASHRAM, J.P. NAGAR
JALANDHAR